

Val Gagne Drinking Water System

2022 Annual Summary Report



Table of Contents

| | |
|--|----|
| OVERVIEW | 1 |
| 1.0 INTRODUCTION..... | 2 |
| 2.0 DESCRIPTION OF THE DRINKING WATER SYSTEM | 3 |
| 3.0 LIST OF ALL WATER TREATMENT CHEMICALS USED..... | 3 |
| 4.0 SIGNIFICANT EXPENSES INCCURRED..... | 3 |
| 5.0 DETAILS OF NOTICES REPORTED & SUBMITTED TO THE SPILLS ACTION CENTER..... | 3 |
| 6.0 MICROBIOLOGICAL TESTING..... | 4 |
| 7.0 OPERATIONAL TESTING..... | 4 |
| Raw Water Turbidity..... | 4 |
| Continuous Monitoring in the Treatment Process..... | 4 |
| Chlorine Residuals from the Distribution System..... | 5 |
| Nitrate & Nitrite Results from the Water Treatment Plant..... | 5 |
| Total Trihalomethane (THM's) Results from the Distribution System..... | 5 |
| Total Haloacetic Acid (HAA's) Results from the Distribution System..... | 5 |
| Lead (most recent), pH & Alkalinity Results from the Distribution System..... | 5 |
| Lead (most recent), pH & Alkalinity Results from Non - Residential Plumbing..... | 6 |
| Summary of Most Recent Schedule 23 Inorganic Results from the Water Treatment Plant | 6 |
| Summary of Most Recent Schedule 24 Organic Results from the Water Treatment Plant... | 6 |
| Sodium Results (Most Recent) from the Water Treatment Plant | 7 |
| Fluoride Results (Most Recent) from the Water Treatment Plant | 8 |
| Inorganic or Organic Test Results that Exceeded Half the Standard | 8 |
| Additional Testing Performed in Accordance with a Legal Instrument..... | 8 |
| 8.0 REQUIREMENTS THE SYSTEM FAILED TO MEET | 8 |
| 9.0 SUMMARY OF FLOW RATES AND QUANTITIES | 8 |
| 10.0 Conclusion | 10 |



OVERVIEW

Municipalities throughout Ontario are required to comply with Ontario Regulation 170/03 made under the *Safe Drinking Water Act*, 2002. The Act was passed following recommendations made by Commissioner O'Conner after the Walkerton Inquiry. The Act's purpose is to protect human health through the control and regulation of drinking-water systems. O. Reg. 170/03 regulates drinking water testing, use of licensed laboratories, treatment requirements and reporting requirements.

Section 11 of O. Reg. 170/03 requires the owner to produce an Annual Report which must include the following:

- Description of system and chemical(s) used
- Summary of any adverse water quality reports and corrective actions
- Summary of all required testing
- 4. Description of any major expenses incurred to install, repair or replace equipment

This Annual Report must be completed by February 28 of each year.

Schedule 22 of the regulation requires that a Summary Report for Municipalities be prepared which must be presented and accepted by Council by March 31 of each year for the preceding calendar year reporting period.

The report must list the requirements of the Act, its regulations, the system's Drinking Water Works Permit (DWWP), Municipal Drinking Water Licence (MDWL), Certificate of Approval (if applicable), and any Provincial Officer Order the system failed to meet during the reporting period. The report must also specify the duration of the failure, and for each failure referred to, describe the measures that were taken to correct the failure.

The *Safe Drinking Water Act*, 2002 and the drinking water regulations can be viewed at the following website: <http://www.e-laws.gov.on.ca>.

To enable the Owner to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report.

- A summary of the quantities and flow rates of water supplied during the reporting period, including the monthly average and the maximum daily flows.
- A comparison of the summary to the rated capacity and flow rates approved in the systems approval, drinking water works permit or municipal drinking water licence or a written agreement if the system is receiving all its water from another system under an agreement.

The Annual and Summary Reports have been combined and presented to council as the Val Gagne Drinking Water System 2022 Annual Summary Report.



1.0 INTRODUCTION

Drinking-Water System Name: VAL GAGNE DRINKING WATER SYSTEM
Drinking-Water System No.: 210001674
Drinking-Water System Owner: The Corporation of the Township of Black River - Val Gagne
Drinking-Water System Category: Small Municipal, Residential System
Municipal Drinking Water Licence No.: 204-102 (Issue 6 - April 23, 2021)
 204-102 (Issue 7 - January 5, 2022)
 204-102 (Issue 8 - March 14, 2022)
Drinking Water Work Permit No.: 204-202 (Issue 5 - June 2, 2017)
 204-202 (Issue 6 - March 14, 2012)
Permit to Take Water No: P-300-1077256711 (Issued October 1, 2020)
Period being reported on: January 1, 2022 to December 31, 2022

Does your Drinking Water System serve more than 10,000 people? No

Is your annual report available to the public at no charge on a web site on the Internet? No

Location where Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Black River - Matheson Municipal Office
 429 Park Lane,
 Matheson ON P0K 1N0

Drinking Water Systems that receive drinking water from the Val Gagne Drinking Water System

| Drinking Water System Name | Drinking Water System Number |
|-----------------------------------|-------------------------------------|
| Val Gagne Drinking Water System | 210001674 |

The Annual Report was provided to all connected Drinking Water System owners

The Ontario Clean Water Agency prepared the 2022 Annual Summary Report for the Val Gagne Drinking Water System and provided a copy to the system owner; the Township of Black River - Matheson. The Val Gagne Drinking Water System is a stand-alone system that does not receive water from or send water to another system.

System users are notified that the Annual Report is available through:

- Public access/notice via newspaper/website



2.0 DESCRIPTION OF THE DRINKING WATER SYSTEM

The Val Gagne water treatment plant is a Class 1 facility owned by the Corporation of the Township of Black River-Matheson and operated by the Ontario Clean Water Agency (OCWA). The facility is located west of Lessard Street in the community of Val Gagne and provides drinking water to approximately 175 residents.

Well 1 is the main production well and is located near Highway 11 on the south side of Country Lane Road. It is a deep drilled groundwater well that is 150 mm in diameter and 22.9 m deep. The well is pumped at the rate of 158.9 L/min by a 2.23 kW submersible deep well pump. The water is pumped to the Val Gagne water treatment via a 1027 meter long watermain. The sodium levels in the well have been increasing over the last 15 to 20 years; the cause of this is being investigated.

Well 6 is a backup well located within the water treatment plant building. It is a drilled groundwater well that is 200 mm in diameter and 56.4 m deep. It is equipped with a submersible pump, rated at 46 L/min at a TDH of 62 m, with a 50 mm diameter discharge line connected to a common well pump header. This well is for emergency use only but it is run at least monthly for testing and sampling.

The main plant houses the disinfection system. Sodium hypochlorite is injected directly into the well pump discharge header by two pace-to-flow metering pumps (one duty and one standby). The sodium hypochlorite is stored in a 275 L double-walled tank equipped with secondary spill containment. An in-ground reservoir with a storage capacity of 550 m³ serves as the chlorine contact chamber and provides water storage for the distribution system. Water is pumped into the distribution system by 3hp submersible high lift pumps with VFD's, each rated at 2.5 L/s with a TDH of 62 m. A diesel driven high flow pump is also available to deliver water at the rate of 2270 L/min during emergencies. Also, a 60 kW (208 V) 3-phase generator will start automatically if the power fails.

A baffled contact tank is used during scheduled cleaning of the reservoir. The chlorinated water is directed to the tank to provide sufficient contact time before entering the distribution system.

3.0 LIST OF ALL WATER TREATMENT CHEMICALS USED

- Sodium Hypochlorite - disinfection

4.0 SIGNIFICANT EXPENSES INCURRED

- Engineering services to investigate high sodium levels in Well #1
- Operations and maintenance costs

5.0 DETAILS OF NOTICES REPORTED & SUBMITTED TO THE SPILLS ACTION CENTER

Loss of Pressure / Boil Water Advisory

| | |
|----------------|---|
| AWQI # | 159128 |
| Date | July 13, 2022 |
| Details | Major watermain break on Church street could not be isolated (could not find valve) and the water treatment plant was having a hard time keeping up with the demand so the pumps had to be throttled down to avoid emptying the reservoir. This resulted in very low flows and a significant loss of pressure to the entire town. BWA issued for entire system. |



| | |
|--------------------------|--|
| Corrective Action | <p>Boil Water Advisory issued by the Owner and Operating Authority and confirmed by the Porcupine Health Unit.</p> <p>Notices distributed door to door by owner.</p> <p>The watermain break repair was completed July 14, 2022 at approximately 1:00 am in the morning and then the system was flushed thoroughly.</p> <p>First set of samples were taken at four locations on July 14, 2022 and then the second set was collected at the same four locations, 24 to 48 hrs apart, on July 15, 2022.</p> <p>All results came back clear. The Porcupine Health Unit was notified and provided with results on July 16, 2022 and then they lifted the Boil Water Advisory.</p> |
|--------------------------|--|

6.0 MICROBIOLOGICAL TESTING

| Sample Type | Range of Results (<i>min to max</i>) | | | | |
|--------------|--|----------------|----------------|------------------|-------------|
| | No. of Samples | <i>E. coli</i> | Total Coliform | # of HPC Samples | HPC Results |
| Raw - Well 1 | 13 | 0 to 0 | 0 to 0 | N/A | N/A |
| Raw - Well 6 | 13 | 0 to 0 | 0 to 0 | N/A | N/A |
| Distribution | 30 | 0 to 0 | 0 to 0 | 30 | <10 to 40 |

Maximum Allowable Concentration (MAC) for distribution samples: *E. coli* = 0 Counts/100 mL and Total Coliforms = 0 Counts/100 mL

"<" denotes less than the laboratory's method detection limit.

Note: One microbiological sample is collected and tested each month from the raw water supply and one every two weeks from the distribution system.

7.0 OPERATIONAL TESTING

Raw Water Turbidity

| Location | No. of Samples | Range of Results (<i>min to max</i>) | Unit of Measure |
|----------|----------------|--|-----------------|
| Well 1 | 12 | 0.11 to 0.62 | NTU |
| Well 6 | 12 | 0.86 to 1.61 | |

Continuous Monitoring in the Treatment Process

| Parameter | No. of Samples | Range of Results (<i>min to max</i>) | Unit of Measure | Standard |
|---------------|----------------|--|-----------------|----------|
| Free Chlorine | 8760 | 0.45 to 2.00 | mg/L | N/A |

Notes: For continuous monitors 8760 is used as the number of samples.

**Chlorine Residuals from the Distribution System**

| Parameter | No. of Samples | Range of Results (min to max) | Unit of Measure | Standard |
|---------------|----------------|----------------------------------|-----------------|----------|
| Free Chlorine | 115 | 0.56 to 1.33 | mg/L | 0.05 |

Note: in the distribution system, at least two samples for free chlorine residual testing must be taken at least 48-hours apart and taken during the same week, each week.

Nitrate & Nitrite Results from the Water Treatment Plant

| Date of Sample | Nitrate Result Value (mg/L) | Nitrite Result Value (mg/L) | Exceedance |
|----------------|--------------------------------|--------------------------------|------------|
| January 4 | 0.77 | <0.05 | No |
| April 11 | 0.83 | <0.05 | No |
| July 5 | 0.9 | <0.01 | No |
| October 11 | 0.75 | <0.05 | No |

Maximum Acceptable Concentration (MAC) for Nitrate = 10 mg/L

MAC for Nitrite = 1.0 mg/L

Total Trihalomethane (THM's) Results from the Distribution System

| Date of Sample | Result Value (ug/L) | Four Quarter Running Average | Exceedance |
|----------------|---------------------|------------------------------|------------|
| January 4 | 8.7 | 14.1 | No |
| April 11 | 8.2 | 11.2 | No |
| July 6 | 14.4 | 13.3 | No |
| October 11 | 32.8 | 16.0 | No |

Maximum Acceptable Concentration (MAC) = 100 ug/L (Four Quarter Running Average)

Total Haloacetic Acid (HAA's) Results from the Distribution System

| Date of Sample | Result Value (ug/L) | Four Quarter Running Average | Exceedance |
|----------------|---------------------|------------------------------|------------|
| January 4 | <8 | 9.2 | No |
| April 11 | <8 | 8.25 | No |
| July 5 | <8 | 8.86 | No |
| October 11 | <9 | 8.25 | No |

Maximum Acceptable Concentration (MAC) = 80 ug/L (Four Quarter Running Average)

Lead (most recent), pH & Alkalinity Results from the Distribution System

| Date of Sample | # of Samples | Range of Results (min to max) | | |
|--------------------|--------------|-------------------------------|---------------------------|---------------------|
| | | pH Results | Alkalinity Results (mg/L) | Lead Results (ug/L) |
| April 14, 2022 | 1 | 7.0 | 308 | 0.3 (April 7, 2020) |
| September 20, 2022 | 1 | 7.6 | 306 | 0.2 (Oct 15, 2020) |

MAC for Lead -10 ug/L

Note: The system is required to test for total alkalinity and pH in one distribution sample collected during the period of December 15 to April 15 and one distribution sample during the period of June 15 to October 15. This testing is required in every 12-month period with lead testing in every third 12-month period. The next round of lead sampling will be completed in April and October of 2023.

**Lead (most recent), pH & Alkalinity Results from Non - Residential Plumbing**

| Date of Sample | # of Samples | pH Result | Temp (°C) | Lead Results (ug/L) |
|--------------------|--------------|-----------|-----------|---------------------|
| April 7, 2020 | 1 | 7.3 | 13.4 | 0.5 |
| September 21, 2020 | 1 | 7.8 | 16.5 | 0.5 |

Sampling required every third 12-month period. Sampling Periods: December 15 to April 15; and June 15 to October 15

Note: The Val Gagne Drinking Water System was required to complete Reduced Lead Sampling in both sampling periods in 2020. As such the system was required to test for lead in five residential plumbing samples, one non-residential plumbing sample and one distribution sample. If not more than 10% of plumbing samples were less than 10 ug/L each period the system would be exempt for plumbing requirements but the system was granted relief from collecting any residential samples in 2020 due to the on-going pandemic. Lead sampling for residential plumbing will resume in 2023.

Summary of Most Recent Schedule 23 Inorganic Results from the Water Treatment Plant

Sample Date: September 21, 2020

| Parameter (ug/L) | Result Value | Maximum Acceptable Concentration | Exceedance |
|------------------|--------------|----------------------------------|------------|
| Antimony | <0.5 | 6 | No |
| Arsenic | 1 | 10 | No |
| Barium | 60 | 1000 | No |
| Boron | 9 | 5000 | No |
| Cadmium | <0.1 | 5 | No |
| Chromium | <1 | 50 | No |
| Mercury | <0.1 | 0.001 | No |
| Selenium | 0.3 | 10 | No |
| Uranium | 5 | 20 | No |

Note: Sampling required once every 60 months (next sample scheduled for October 2025)

Summary of Most Recent Schedule 24 Organic Results from the Water Treatment Plant

Sample Date: September 21, 2020

| Parameter | Result Value | Unit of Measure | Standard | Exceedance |
|---|--------------|-----------------|----------|------------|
| 1,1-Dichloroethylene | <0.3 | ug/L | 14 | No |
| 1,2-Dichlorobenzene | <0.3 | ug/L | 200 | No |
| 1,2-Dichloroethane | <0.3 | ug/L | 5 | No |
| 1,4-Dichlorobenzene | <0.3 | ug/L | 5 | No |
| 2,3,4,6-Tetrachlorophenol | <0.3 | ug/L | 100 | No |
| 2,4,6-Trichlorophenol | <0.2 | ug/L | 100 | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | <0.342 | ug/L | 100 | No |
| 2-4 Dichlorophenol | <0.2 | ug/L | 900 | No |
| Alachlor | <0.226 | ug/L | 5 | No |
| Atrazine + N-dealkylated metabolites | <0.5 | ug/L | 5 | No |
| Azinphos-methyl | <0.169 | ug/L | 20 | No |
| Benzene | <0.1 | ug/L | 1 | No |
| Benzo(a)pyrene | <0.01 | ug/L | 0 | No |
| Bromoxynil | <0.0911 | ug/L | 5 | No |



| Parameter | Result Value | Unit of Measure | Standard | Exceedance |
|----------------------|--------------|-----------------|----------|------------|
| Carbaryl | <2 | ug/L | 90 | No |
| Carbofuran | <4 | ug/L | 90 | No |
| Carbon Tetrachloride | <0.2 | ug/L | 2 | No |
| Chlorobenzene | <0.5 | ug/L | 80 | No |
| Chlorpyrifos | <0.169 | ug/L | 90 | No |
| Diazinon | <0.169 | ug/L | 20 | No |
| Dicamba | <0.0797 | ug/L | 120 | No |
| Dichloromethane | <1 | ug/L | 50 | No |
| Diclofop-methyl | <0.114 | ug/L | 9 | No |
| Dimethoate | <0.169 | ug/L | 20 | No |
| Diquat | <0.2 | ug/L | 70 | No |
| Diuron | <10 | ug/L | 150 | No |
| Glyphosate | <20 | ug/L | 280 | No |
| Malathion | <0.169 | ug/L | 190 | No |
| MCPA | <5.69 | ug/L | 230 | N/A |
| Metolachlor | <0.113 | ug/L | 50 | No |
| Metribuzin | <0.113 | ug/L | 80 | No |
| Paraquat | <0.1 | ug/L | 10 | No |
| Pentachlorophenol | <0.3 | ug/L | 3 | No |
| Phorate | <0.113 | ug/L | 60 | No |
| Picloram | <0.0797 | ug/L | 2 | No |
| Prometryne | <0.0564 | ug/L | 1 | No |
| Simazine | <0.169 | ug/L | 10 | No |
| Terbufos | <0.113 | ug/L | 1 | No |
| Tetrachloroethylene | <0.3 | ug/L | 10 | No |
| Total PCB's | <0.07 | ug/L | 190 | No |
| Triallate | <0.113 | ug/L | 5 | No |
| Trichloroethylene | <0.2 | ug/L | 5 | No |
| Trifluralin | <0.113 | ug/L | 45 | No |
| Vinyl Chloride | <0.1 | ug/L | 1 | No |

Note: Sampling required once every 60 months (next sample scheduled for October 2025)

Sodium Results (Most Recent) from the Water Treatment Plant

| Date of Sample | # of Samples | Result Value | Unit of Measure | Standard | Exceedance |
|--------------------|--------------|--------------|-----------------|----------|--------------------|
| September 21, 2020 | 1 | 26.4 | mg/L | 20 | Yes (AWQI #152285) |
| October 2, 2020 | 1 | 22.8 | mg/L | 20 | Yes |

Note: Sample required every 60 months. Next sampling scheduled for October 2025

Note: The sodium levels in Well 1 have been increasing over the last 15 to 20 years; the cause of this is being investigated.

**Fluoride Results (Most Recent) from the Water Treatment Plant**

| Date of Sample | No. of Samples | Result Value | Unit of Measure | Standard | Exceedance |
|--------------------|----------------|--------------|-----------------|----------|------------|
| September 21, 2020 | 1 | 0.06 | mg/L | 1.5 | No |

Note: Sample required every 60 months. Next sampling scheduled for October 2025

Inorganic or Organic Test Results that Exceeded Half the Standard

No inorganic or organic parameter(s) listed in Schedule 23 and 24 of Ontario Regulation 170/03 exceeded half the standard found in Schedule 2 of the Ontario Drinking Water Standard (O. Reg. 169/03) during the reporting period.

Additional Testing Performed in Accordance with a Legal Instrument.

No additional sampling or testing was required in 2022.

8.0 REQUIREMENTS THE SYSTEM FAILED TO MEET

The Val Gagne Drinking Water system met all requirements in 2022

9.0 SUMMARY OF FLOW RATES AND QUANTITIES

The following tables indicate the quantities and flow rates of water taken and produced during the reporting period, including monthly average flows, maximum daily flows and the total monthly volumes. A comparison of the water data is made to the rated capacity and flow rates specified in the system's Permit to Take Water and the Municipal Drinking Water License.

Any raw water flow rate exceedances in 2022 were checked and determined to be inflated numbers due to momentary spikes on pump start up/shutdown that were momentary and are not representative. The actual maximum flow rates have been depicted in the tables below.

Well 1 - Summary of Water Taking

Regulated by Permit to Take Water (PTTW) #P-300-1077256711, Issued October 1, 2020

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Year to Date |
|---|------|------|------|------|------|------|------|------|------|------|------|------|--------------|
| Total Volume (m ³) | 2920 | 2360 | 2564 | 2343 | 2127 | 2125 | 2455 | 2036 | 1928 | 1846 | 1783 | 1881 | 26368 |
| Average Volume (m ³ /d) | 94.2 | 84.3 | 82.7 | 78.1 | 68.6 | 70.8 | 79.2 | 65.7 | 64.3 | 59.6 | 59.4 | 60.7 | 72.2 |
| Maximum Volume (m ³ /d) | 137 | 102 | 103 | 95 | 139 | 98 | 204 | 89 | 95 | 84 | 74 | 79 | 204 |
| PTTW - Maximum Allowable Volume (m ³ /day) | 229 | 229 | 229 | 229 | 229 | 229 | 229 | 229 | 229 | 229 | 229 | 229 | 229 |
| Maximum Flow Rate (L/min) | 142 | 142 | 142 | 143 | 145 | 148 | 151 | 156 | 143 | 139 | 139 | 145 | 156 |
| PTTW - Maximum Allowable Flow Rate (L/min) | 159 | 159 | 159 | 159 | 159 | 159 | 159 | 159 | 159 | 159 | 159 | 159 | 159 |

The system's Permit to Take Water allows the municipality to withdraw a maximum volume of 229 cubic meters from Well 1 each day. A review of the raw water flow data indicates that the system never exceeded this allowable limit having a maximum volume of 204 m³.

The Permit also allows a maximum flow rate of 159 L/minute which was not exceeded either as the maximum flow rate was 156 L/minute.



Well 6 - Summary of Water Taking

Regulated by Permit to Take Water (PTTW) #P-300-1077256711, Issued October 1, 2020

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Year to Date |
|---|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------------|
| Total Volume (m ³) | 2 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 13 |
| Average Volume (m ³ /d) | 0.06 | 0.04 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.03 | 0.04 |
| Maximum Volume (m ³ /d) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| PTTW - Maximum Allowable Volume (m ³ /day) | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 | 66.24 |
| Maximum Flow Rate (L/min) | 42 | 35 | 38 | 36 | 46 | 46 | 40 | 44 | 38 | 37 | 40 | 41 | 46 |
| PTTW - Maximum Allowable Flow Rate (L/min) | 46 | 46 | 46 | 46 | 46 | 46 | 46 | 46 | 46 | 46 | 46 | 46 | 46 |

The system’s Permit to Take Water allows the municipality to withdraw a maximum volume of 66.24 cubic meters from Well 6 each day. A review of the raw water flow data indicates that the system never exceeded this allowable limit having a maximum volume of 1 m³.

The Permit also allows a maximum flow rate of 46 L/minute which was not exceeded either as the maximum flow rate was 46 L/minute.

Treated Water Supplied to the Distribution System

Regulated by Municipal Drinking Water Licence (MDWL) #204-102 - Issue 6 (Issued April 23, 2021), #204-102 - Issue 7 (Issued January 5, 2022), and #204-102 - Issue 8 (Issued March 14, 2022)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Year to Date |
|---|------|------|------|------|------|------|------|------|------|------|------|------|--------------|
| Total Volume (m ³) | 2118 | 1530 | 1687 | 1526 | 1812 | 1848 | 2169 | 1734 | 1616 | 1744 | 1655 | 1753 | 21192 |
| Average Volume (m ³ /d) | 68 | 55 | 54 | 51 | 58 | 62 | 70 | 56 | 54 | 56 | 55 | 57 | 58 |
| Maximum Volume (m ³ /d) | 108 | 73 | 84 | 70 | 113 | 88 | 449 | 69 | 81 | 80 | 63 | 67 | 449 |
| MDWL - Rated Capacity (m ³ /day) | 233 | 233 | 233 | 233 | 233 | 233 | 233 | 233 | 233 | 233 | 233 | 233 | 233 |
| % Rated Capacity | 46 | 31 | 36 | 30 | 48 | 38 | 193 | 30 | 35 | 34 | 27 | 29 | 193 |

Schedule C, Section 1.1 of MDWL No. 204-102 states that the maximum daily volume of treated water that flows from the treatment subsystem to the distribution system shall not exceed a maximum flow rate of 233 m³ on any calendar day. The Val Gagne DWS was under the limit all year except on July 13 when the total volume of water supplied to the distribution system was 449 m³ due to a large watermain break.




Figure: Volume of Treated Water Supplied to the Distribution System - A comparison of the rate specified in the system’s Municipal Drinking Water Licence to the average and maximum volumes entering the distribution system.

Comparison of the Flow Summary to Systems Licence & Permit

| | | |
|--------------------------------------|------------|-----------------------------|
| Rated Capacity of the Plant (MDWL) | 233 m³/day | |
| Average Daily Flow for 2022 | 58 m³/day | 25 % of the rated capacity |
| Maximum Daily Flow for 2022 | 449 m³/day | 193 % of the rated capacity |
| Total Treated Water Produced in 2022 | 21,192 m³ | |

The Val Gagne water treatment plant is rated to 233 cubic meters of water per day as specified in the system’s Municipal Drinking Water Licence. The average daily flow was 58 m³ per day, which is 25% of the rated capacity. This information clearly shows that the plant is well within its rated capacity and is able to meet current demands of consumers.

10.0 CONCLUSION

The Val Gagne Drinking Water System completed all required sampling and monitoring in 2022 and was able to meet the communities demand for drinking water while complying with the terms and conditions outlined in its Drinking Water Works Permit and Municipal Drinking Water Licence. The system also complied with the regulatory requirements of the Safe Drinking Water Act and its Regulations.